



DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER POLLUTION CONTROL
6TH FLOOR, L&C ANNEX, 401 CHURCH ST, NASHVILLE, TN 37243

NOTICE OF INTENT (NOI)

for discharges of treated groundwater associated with

UNDERGROUND STORAGE TANK (UST) REMEDIATION

This application is for: ☒ New Permit ☐ Permit Reissuance ☐ Permit Modification

(If this NOI is submitted for Permit Modification provide the existing permit tracking number: **TNG83**)

| | |
|--|---|
| Site Name: Ann's Market and Deli | County: Roane |
| Street Address or Location: 5512 Harriman Highway, Oliver Springs, TN | *Latitude: 36 1.42 |
| | *Longitude: 88 22.26 |
| UST Site ID Number: 2-730175 | Attach a site location (topographic) map <input checked="" type="checkbox"/> Map attached |

| | | | | |
|--|--|--|--|---------------------|
| Owner or Operator: (the person or legal entity which controls site's operation; this may or may not be the same as the site name or the official contact name) | | | | |
| Mr. Tony Melhorn | | | | |
| 1 | Official Contact Person Name: (individual responsible for a site) Mr. Tony Melhorn | | Title or Position: owner | |
| | Mailing Address: 143 Stripling Rd | | City: Oliver Springs | State: TN |
| | Phone: 865-435-0070 «Extension» | | Zip: 37840 | |
| E-mail: melhornmotors@gmail.com | | | | |
| 2 | Local Contact Person Name: (if appropriate, write "same as #1") James C. Bolton | | Title or Position: agent for Mr. Melhorn | |
| | Site Address: (this may or may not be the same as street address) P. O. Box 23680 | | Site City: Knoxville | State: TN |
| | Phone: 865-671-4025 | | Zip: 37933 | |
| E-mail: jamesbolton@chartertn.net | | | | |

Write in the box (to the right) or circle the number (above) to indicate where to send correspondence:

2

UST REMEDIATION FACILITY DESCRIPTION

| | |
|--|---------------------------|
| Treated groundwater from site enters following stream(s) and/or lake(s): (for each outfall, give names and stream miles) Unnamed creek which conjoins with Indian Creek which conjoins with Poplar Creek which drains into the Clinch River. | No. of outfalls: 1 |
| List type of product(s) currently or previously stored in tanks located at the site: gasoline, diesel | |
| Description of contamination, assessment study, extent of contamination, etc. Attach additional pages if necessary. gasoline range organics | |
| Description and design capacity of treatment process and facilities. Vacuum extraction, air stripping and granulated activated carbon before discharge, Discharge est 5000 GPD | |
| Select discharge type (continuous means more than 4 days at a time): <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | |
| Expected starting date for groundwater treatment, and estimated life of remediation project: June 1, 2011 | |

CERTIFICATION AND SIGNATURE

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

James C. Bolton
Printed Name

agent for
Official Title

James C. Bolton
Signature

3-3-11
Date

STATE USE ONLY

Submit the original of the completed and signed form to:
UST NOI Processing
Tennessee Division of Water Pollution Control
6th Floor L&C Annex, 401 Church Street
Nashville, TN 37243

RECEIVED

MAR 09 2011

TN Division Of Water
Pollution Control

RDAs 2399 and 2400



DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER POLLUTION CONTROL
6TH FLOOR, L&C ANNEX, 401 CHURCH ST, NASHVILLE, TN 37243

NOTICE OF INTENT (NOI)

for discharges of treated groundwater associated with

UNDERGROUND STORAGE TANK (UST) REMEDIATION

| | | | | |
|---------------|---------------------------|-----|--------------------|------------------------------|
| Received Date | Reviewer | EFO | NOC Date | Tracking No. TNG83 |
| | Impaired Receiving Stream | | High Quality Water | T & E Aquatic Fauna |

RECEIVED


MAR 09 2011

Submit the original of the completed and signed form to:

**UST NOI Processing
Tennessee Division of Water Pollution Control
6th Floor L&C Annex, 401 Church Street
Nashville, TN 37243**

**TN Division Of Water
Pollution Control**

Fig. 1: ANN'S MARKET AND DELI
(Facility ID # 2-730175)
Topographic Map



Site Information

Topographic Map: Windrock, TN
Topographic Id: 129-SE

Lat: 36° 01.407'
Long: 84° 22.272'

0 2000 ft
SCALE

RECEIVED

MAR 09 2011

TN Division Of Water
Pollution Control